

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

Influent Flow and Loading

1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.0398	x	143	x	8.34	=	47
February	0.0391	x	151	x	8.34	=	49
March	0.0488	x	106	x	8.34	=	43
April	0.0716	x	133	x	8.34	=	80
May	0.0492	x	158	x	8.34	=	65
June	0.0622	x	179	x	8.34	=	93
July	0.0368	x	244	x	8.34	=	75
August	0.0364	x	189	x	8.34	=	57
September	0.0361	x	180	x	8.34	=	54
October	0.0353	x	175	x	8.34	=	51
November	0.0349	x	205	x	8.34	=	60
December	0.0352	x	147	x	8.34	=	43

2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.087	x	90	=	0.0783
		x	100	=	.087
Design BOD, lbs/day	387	x	90	=	348.3
		x	100	=	387

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

- Yes

Enter last calibration date (MM/DD/YYYY)

0004-04-09

- No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

- Yes

- No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

- Yes

- No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks Holding Tanks Grease Traps

- Yes

- Yes

- Yes

- No

- No

- No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

- Yes

gallons

- No

Holding Tanks

- Yes

gallons

- No

Grease Traps

- Yes

gallons

- No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

- Yes

- No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 **2023**

<p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	0	1	0	0
February	30	27	1	1	0	0
March	30	27	1	1	0	0
April	30	27	2	1	0	0
May	30	27	0	1	0	0
June	30	27	1	1	0	0
July	30	27	0	1	0	0
August	30	27	1	1	0	0
September	30	27	0	1	0	0
October	30	27	0	1	0	0
November	30	27	0	1	0	0
December	30	27	0	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

- Yes
- No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

- Yes
- No
- N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	3	1	0	0
February	30	27	2	1	0	0
March	30	27	3	1	0	0
April	30	27	3	1	0	0
May	30	27	2	1	0	0
June	30	27	2	1	0	0
July	30	27	2	1	0	0
August	30	27	3	1	0	0
September	30	27	3	1	0	0
October	30	27	2	1	0	0
November	30	27	2	1	0	0
December	30	27	0	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				12		
Points per each exceedance with 12 months of discharge:					7	3
Exceedances					0	0
Points					0	0
Total Number of Points						0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is 12/6 = 2.0

1.2 If any violations occurred, what action was taken to regain compliance?

N/A

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Guys Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	3.6	2.103	1	0
February	3.6	2.168	1	0
March	3.6	1.486	1	0
April	3.6	2.015	1	0
May	3.6	2.848	1	0
June	3.6	3.900	1	1
July	3.6	4.700	1	1
August	3.6	4.590	1	1
September	3.6	4.730	1	1
October	3.6	3.990	1	1
November	3.6	3.352	1	0
December	3.6	3.225	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				5
Total Number of Points				50

50

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

DECANT AND WASTE MORE

Total Points Generated	50
Score (100 - Total Points Generated)	50
Section Grade	F

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - SLUDGE																		
Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75									<4.09					0	0
Cadmium		39	85									1.53					0	0
Copper		1500	4300									263					0	0
Lead		300	840									52.1					0	0
Mercury		17	57									<4.48					0	0
Molybdenum	60		75									2.88			0			0
Nickel	336		420									61.2			0			0
Selenium	80		100									7.33			0			0
Zinc		2800	7500									1040					0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)
- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

Compliance Maintenance Annual Report

Gas Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

<p>3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <ul style="list-style-type: none"> ● <input checked="" type="radio"/> >= 180 days (0 Points) ○ <input type="radio"/> 150 - 179 days (10 Points) ○ <input type="radio"/> 120 - 149 days (20 Points) ○ <input type="radio"/> 90 - 119 days (30 Points) ○ <input type="radio"/> < 90 days (40 Points) ○ <input type="radio"/> N/A (0 Points) <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; padding: 2px;">N/A</div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Staffing and Preventative Maintenance (All Treatment Plants)

1. Plant Staffing

1.1 Was your wastewater treatment plant adequately staffed last year?

- Yes
- No

If No, please explain:

Could use more help/staff for:

1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?

- Yes
- No

If No, please explain:

2. Preventative Maintenance

2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?

- Yes (Continue with question 2)
- No (40 points)

If No, please explain, then go to question 3:

2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?

- Yes
- No (10 points)

2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?

- Yes
 - Paper file system
 - Computer system
 - Both paper and computer system
- No (10 points)

0

3. O&M Manual

3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?

- Yes
- No

4. Overall Maintenance /Repairs

4.1 Rate the overall maintenance of your wastewater plant.

- Excellent
- Very good
- Good
- Fair
- Poor

Describe your rating:

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 **2023**

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

JAMES F CHELLEVOLD

Certification No:

33111

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes	X		X	
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X		X	
C	Biological Solids/Sludges	X		X	
P	Total Phosphorus				
N	Total Nitrogen				
D	Disinfection	X		X	
L	Laboratory				
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

2.3 For wastewater treatment facilities with a registered or certified laboratory, is at least one operator that works in the laboratory certified at the basic level in the laboratory (L) subclass?

- Yes
- No
- N/A – Wastewater treatment facility does not have a registered or certified laboratory

2.4 For wastewater treatment facilities that own and operate a sanitary sewage collection system, has at least one operator been designated the OIC for sanitary sewage collection system and certified at the basic level in the sanitary sewage collection system (SS) subclass?

- Yes
- No
- N/A – Owner of the Wastewater treatment facility does not own and operate a sanitary sewage collection system

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

<input type="checkbox"/> An arrangement with another certified operator <input checked="" type="checkbox"/> An arrangement with another community with a certified operator <input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) If "None of the above" is selected, please explain: <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div>	0
4. Continuing Education Credits 4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? OIT and Basic Certification: <input type="radio"/> Averaging 6 or more CECs per year. <input type="radio"/> Averaging less than 6 CECs per year. Advanced Certification: <input type="radio"/> Averaging 8 or more CECs per year. <input type="radio"/> Averaging less than 8 CECs per year.	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="DAWN R MCCANN"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="608-735-4341"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="dmccann@gaysmills.org"/></p>																	
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p>● Yes (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: <input style="width: 60px;" type="text" value="2023"/></p> <p>● 0-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFPP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p>● Yes (0 points)</p> <p>○ No (40 points)</p>	0																
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>																	
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: <input style="width: 60px;" type="text" value="2023"/></p> <p>● 1-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>																	
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%;"></td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 30%; text-align: right;"><input style="width: 100%;" type="text" value="58,700.00"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="2,095.76"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td></td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="60,795.76"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input style="width: 100%;" type="text" value="58,700.00"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	+	\$	<input style="width: 100%;" type="text" value="2,095.76"/>	3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 100%;" type="text" value="60,795.76"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 100%;" type="text" value="0.00"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input style="width: 100%;" type="text" value="58,700.00"/>														
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	+	\$	<input style="width: 100%;" type="text" value="2,095.76"/>														
3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 100%;" type="text" value="60,795.76"/>														
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 100%;" type="text" value="0.00"/>														

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 **2023**

<p>3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) - \$ <input style="width: 100px;" type="text" value="0.00"/></p> <p>3.2.6 Ending Balance as of December 31st for CMAR Reporting Year \$ <input style="width: 100px;" type="text" value="60,795.76"/></p> <p>All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.</p> <p>3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above. <input style="width: 100%; height: 20px;" type="text"/></p> <p>3.3 What amount should be in your Replacement Fund? \$ <input style="width: 100px;" type="text" value="3,500.00"/></p> <p>Please note: If you had a CWFPP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.</p> <p>3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?</p> <p><input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>If No, please explain. <input style="width: 100%; height: 20px;" type="text"/></p>	0																																																
<p>4. Future Planning</p> <p>4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?</p> <p><input checked="" type="radio"/> Yes - If Yes, please provide major project information, if not already listed below. <input type="checkbox"/> <input type="checkbox"/></p> <p><input type="radio"/> No</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th style="width: 5%;">Project #</th> <th style="width: 60%;">Project Description</th> <th style="width: 15%;">Estimated Cost</th> <th style="width: 20%;">Approximate Construction Year</th> </tr> </thead> <tbody> <tr><td>1</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> <tr><td>2</td><td>Work on equipment for Phosphorus removal</td><td>\$400,000</td><td>2025</td></tr> <tr><td>3</td><td>Work on equipment for Phosphorus removal</td><td>\$300,000</td><td>2025</td></tr> <tr><td>4</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> <tr><td>5</td><td>Work on equipment for Phosphorus removal</td><td>\$400,000</td><td>2025</td></tr> <tr><td>6</td><td>Work on equipment for Phosphorus removal</td><td>\$300,000</td><td>2025</td></tr> <tr><td>7</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> <tr><td>8</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> <tr><td>9</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> <tr><td>10</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> <tr><td>11</td><td>Waste Water Treatment Plant Upgrade and Maintenance</td><td>\$180,000</td><td>2007</td></tr> </tbody> </table>		Project #	Project Description	Estimated Cost	Approximate Construction Year	1	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007	2	Work on equipment for Phosphorus removal	\$400,000	2025	3	Work on equipment for Phosphorus removal	\$300,000	2025	4	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007	5	Work on equipment for Phosphorus removal	\$400,000	2025	6	Work on equipment for Phosphorus removal	\$300,000	2025	7	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007	8	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007	9	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007	10	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007	11	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007
Project #	Project Description	Estimated Cost	Approximate Construction Year																																														
1	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
2	Work on equipment for Phosphorus removal	\$400,000	2025																																														
3	Work on equipment for Phosphorus removal	\$300,000	2025																																														
4	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
5	Work on equipment for Phosphorus removal	\$400,000	2025																																														
6	Work on equipment for Phosphorus removal	\$300,000	2025																																														
7	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
8	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
9	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
10	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
11	Waste Water Treatment Plant Upgrade and Maintenance	\$180,000	2007																																														
<p>5. Financial Management General Comments <input style="width: 100%; height: 20px;" type="text"/></p>																																																	
<p>ENERGY EFFICIENCY AND USE</p>																																																	
<p>6. Collection System</p> <p>6.1 Energy Usage</p> <p>6.1.1 Enter the monthly energy usage from the different energy sources:</p> <p>COLLECTION SYSTEM PUMPAGE: Total Power Consumed</p> <p>Number of Municipally Owned Pump/Lift Stations: <input style="width: 50px;" type="text" value="4"/></p>																																																	

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	558	
February	570	
March	589	
April	572	
May	660	
June	463	
July	418	
August	406	
September	334	
October	403	
November	395	
December	390	
Total	5,758	0
Average	480	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

- No
- Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 **2023**

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	274	1.23	223	1.46	188	
February	258	1.09	237	1.37	188	
March	225	1.51	149	1.33	169	
April	201	2.15	93	2.40	84	
May	222	1.53	145	2.02	110	
June	203	1.87	109	2.79	73	
July	202	1.14	177	2.33	87	
August	199	1.13	176	1.77	112	
September	187	1.08	173	1.62	115	
October	206	1.09	189	1.58	130	
November	203	1.05	193	1.80	113	
December	271	1.09	249	1.33	204	
Total	2,651	15.96		21.80		0
Average	221	1.33	176	1.82	131	0

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Guys Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 **2023**

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

Yes

No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

Yes

No (30 points)

N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Did you accomplish them?

Yes

No

If No, explain:

Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

Organizational structure and positions (eg. organizational chart and position descriptions)

Internal and external lines of communication responsibilities

Person(s) responsible for reporting overflow events to the department and the public

Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY)

Does your sewer use ordinance or other legally binding document address the following:

Private property inflow and infiltration

New sewer and building sewer design, construction, installation, testing and inspection

Rehabilitated sewer and lift station installation, testing and inspection

Sewage flows satellite system and large private users are monitored and controlled, as necessary

Fat, oil and grease control

Enforcement procedures for sewer use non-compliance

Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

Equipment and replacement part inventories

Up-to-date sewer system map

A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

A description of routine operation and maintenance activities (see question 2 below)
 Capacity assessment program
 Basement back assessment and correction
 Regular O&M training
 Design and Performance Provisions [NR 210.23 (4) (e)]
 What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?
 State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
 Construction, Inspection, and Testing
 Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]
 Does your emergency response capability include:
 Responsible personnel communication procedures
 Response order, timing and clean-up
 Public notification protocols
 Training
 Emergency operation protocols and implementation procedures
 Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]
 Special Studies Last Year (check only those that apply):
 Infiltration/Inflow (I/I) Analysis
 Sewer System Evaluation Survey (SSES)
 Sewer Evaluation and Capacity Management Plan (SECAP)
 Lift Station Evaluation Report
 Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="30"/>	% of system/year
Root removal	<input type="text" value="0"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="35"/>	% of system/year
Manhole inspections	<input type="text" value="50"/>	% of system/year
Lift station O&M	<input type="text" value="100"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="25"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 **2023**

River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="22.12"/>	Total actual amount of precipitation last year in inches
<input type="text" value="32.85"/>	Annual average precipitation (for your location)
<input type="text" value="6.72"/>	Miles of sanitary sewer
<input type="text" value="4"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="0"/>	Number of basement backup occurrences
<input type="text" value="0"/>	Number of complaints
<input type="text" value=".087"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.00"/>	Basement backups (number/sewer mile)
<input type="text" value="0.00"/>	Complaints (number/sewer mile)
<input type="text" value="0.0"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text" value="0.0"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes
- No

If Yes, please describe:

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:

5/31/2024

2023

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years: 2023 VERY DRY YEAR
5.4 What is being done to address infiltration/inflow in your collection system? TELEWISE AND LOCATE PROBLEM AREAS

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Gays Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Grading Summary

WPDES No: 0022268

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Phosphorus	F	0	3	0
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			32	116
GRADE POINT AVERAGE (GPA) = 3.62				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

Guys Mills Wastewater Treatment Facility

Last Updated: Reporting For:
5/31/2024 2023

Resolution or Owner's Statement

Name of Governing Body or Owner:	Village of Guys Mills
Date of Resolution or Action Taken:	06/03/2024
Resolution Number:	R, 2024-02
Date of Submittal:	
ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):	
Influent Flow and Loadings: Grade = A	
Effluent Quality: BOD: Grade = A	
Effluent Quality: TSS: Grade = A	
Effluent Quality: Phosphorus: Grade = F	WORKING ON WASTING AND DECANTING MORE TO KEEP SLUDGE THICKNESS LESS
Biosolids Quality and Management: Grade = A	
Staffing: Grade = A	
Operator Certification: Grade = A	
Financial Management: Grade = A	
Collection Systems: Grade = A (Regardless of grade, response required for Collection Systems if SSOs were reported)	
ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS (Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00) G.P.A. = 3.62	

